

Civil Surgeon Office


Tarn Taran

No.CSTT 18

Date: 03-02-2021

To Whom It May Concern

This is to certify that we have inspected APKF Public School Goindwal Road Adda Sheikh Chak , District Tarn Taran. After inspecting their Toilets, Kitchen, Canteen and other rooms, we can certify that their Cleanliness and sanitation is good. Their water is Potable through RO system as per report of rural water supply and sanitation department. This certificate is valid for one year from the date of issue. No Health Hazard is seen in the premises of the school.


District Epidemiologist
District Epidemiologist
Civil Surgeon
Tarn Taran
Tarn Taran

357

Hi Tech Multi District Water Testing Laboratory.
Water Supply & Sanitation Complex,
Near Jaura Phatak Amritsar.

ANALYSIS REPORT FOR THE PHYSICAL & CHEMICAL AND BACTERIOLOGICAL
EXAMINATION OF THE WATER SAMPLE

Block: T.T.


Particulars of Sample

1. Name of the Place: APKF Public Sch,
2. Source of the sample: R.O.
3. Whether water chlorinated: -
4. Date of Collection: 2-2-2021
5. Name and designations of the officer who collected Sample: Principal.
6. Date and Time of Commencing of Examination: 3-2-2021

CHEMICAL TEST REPORT

Sr. No.	TEST	DESIRABLE LIMIT	PERMISSIBLE LIMIT	RESULT
1	Turbidity (NTU)	5.0	10	0.1
2	Color (Physically)			6.8
3	pH			6.5
4	Total Dissolved Solids, PPM	500	600	50
5	Alkalinity (as calcium carbonate) mg/L	200	600	45
6	Total Hardness (as Ca Co) mg/L	200	600	-
7	Residual Chlorine mg/L	0.2	1.0	0.01
8	Iron mg/L	0.3	No Relaxation	0.01
9	Flourides (as F) mg/L	1.0	1.5	5
10	Nitrate (as No ₃) mg/L	45	No Relaxation	-
11	Bacteriological Examination	After 24 hrs to 48 hrs		-
	Total Coliform			-
	E.Coli			-

The water is Potable / Not Potable according to the parameter tested above.

Chemist 
Hi Tech Multi Distt.
Water Testing Laboratory
Deptt. Of W/S & Sanitation,
Amritsar.

1. Sample is not drawn by us unless otherwise stated.
2. Sample consumed in Testing.